

CONSTRUCTION INDUSTRY COUNCIL

CIC GREEN PRODUCT CERTIFICATION

Assessment Standard

Cooling Tower



CIC GREEN
PRODUCT CERTIFICATION

(Version 2.0)

Copyright © 2025 Construction Industry Council

All rights reserved. No part of this document may be reproduced, stored in a retrieval system or transmitted, in any form or by any means, whether electronic or mechanical, including photocopying and recording, without the written permission of the Construction Industry Council. If there is any inconsistency or ambiguity between the English version and the Chinese version, the English version shall prevail.

Cooling Tower

Summary of Assessment Criteria

CORE CRITERIA

Criteria	Requirements	Verification	Points		Index
			Basic	+Bonus	
Product Information	Provide following information with delivered products or made accessible to public: - Country of origin - Basic product specifications - Installation method - Instructions for consumer product disposal - Operation & Maintenance Manual	Documentation including but not limited to product label, product catalogue, and written declaration with date-stamped photographs.	5	-	4.1.1
ENVIRONMENT					
Human Toxicity and Ecosystem Impact	Noise Level: Product should not exceed the limits as stated in Table 2 and Table 3.	Documentation including but not limited to product catalogue, and test report	10	-	4.4.3.2
PERFORMANCE					
Efficiency Metrics	Energy Efficiency: Cooling towers shall fulfil the requirement outlined in index 4.5.1.1	Documentation including but not limited to product catalogue, and test report	15	+5/ +10	4.5.1.1
	Water Efficiency: Evaporation loss and drift loss shall not exceed 1% and 0.005% of water circulation rate respectively, under maximum air flow and maximum water flow.	Documentation including but not limited to product catalogue and test report	10	-	4.5.1.2
	Thermal Performance: Under specific operating conditions as stated in Table 4, the percentage of the measured cooling capacity and the designed cooling capacity shall not be less than the following limits: ≥ 90% (10 Basic Points) ≥ 95% (+5 Bonus Points)	Documentation including but not limited to product catalogue and test report	10	+5	4.5.1.4
		Subtotal:	50	+15	

NON-CORE CRITERIA

Criteria	Requirements	Verification	Points	Index
			+Bonus	
CARBON				
CFP quantification/ EPD Report	Provide a life cycle assessment report with the carbon footprint of products (CFP) of product, covering at least A1 to A3 endorsed by a third-party critical review or provide an Environmental Product Declaration (EPD).	CFP quantification report OR Environmental Product Declaration (EPD)	+5	4.2.1
RESOURCE				
Circularity	Recyclability: Developed a recycling plan for the product and declared options for reuse, recycling, recovery and disposal. The plan shall include the following and made available to public.	Recycling plan	+5	4.3.1.1
	Packaging Requirement: The packaging materials shall achieve either of the followings: The packaging materials shall not contain halogenated plastics OR The packaging materials shall be comprised of 100% recycled materials, readily recyclable materials or decomposable materials OR The packaging shall not be impregnated, labelled, coated or otherwise treated in a manner, which would prevent or significantly limit recycling.	Documentation such as written declaration supporting documents	+5	4.3.1.2
	Design For Disassembly: - The fans and motors shall be demountable from enclosure for cleaning, repair, replacement or maintenance purpose. - Fan impeller scroll casing shall be removable for fan blades cleaning.	Documentation including but not limited to product label, product catalogue, and written declaration with date-stamped photographs	+5	4.3.1.3
	Waste Management Plan: Implement effective waste management plan detailing the policies, procedures and/or a waste management program covering manufacturing operations.	Waste management programme	+5	4.3.2.1

Criteria	Requirements	Verification	Points	Index
			+Bonus	
Water Management	Option A: Water Consumption Reporting: Report both potable and non-potable water usage in the production process of the past year.	Water consumption report	+5/ +10	4.3.3.1
	Water Recycling Program: Develop and implement water recycling program during the manufacturing process.	Documentation on water recycling		4.3.3.2
	Option B: Water Management System: Process valid certificate under ISO 14046: Water Footprint Assessment	ISO 14046 Certificate issued by accredited certification body		4.3.3.3
Energy Management	Option A: Energy Management Plan: Implement effective energy management policies and procedures and/or an energy management programme.	Energy management plan	+5/ +10	4.3.4.1
	Option B: Energy Management System: Possess valid certificate under ISO 50001: Energy management systems.	ISO 50001 Certificate issued by accredited certification body		4.3.4.2
ENVIRONMENT				
Environmental Management	Environmental Management System: Manufacturer shall possess valid certification of ISO 14001: Environmental management systems or EU Eco-Management and Audit Scheme (EMAS).	ISO 14001 or EMAS Certificate	+5	4.4.1.1
Regional Products	Regional Manufactured Equipment: The manufacturing location should be located within an 800km radius of HKSAR by road transportation; within a 1,600km radius by rail transportation; or within a 4,000km radius by sea transportation.	Location map	+5	4.4.2.1
Human Toxicity and Ecosystem Impact	Hazardous Substance: Product shall meet the requirements for both paints used and flame retardant in index 4.4.3.1	Laboratory test report(s) or self-declaration letter	+5	4.4.3.1
PERFORMANCE				
Efficiency Metrics	Variable Speed Drives: Variable Speed Drives shall be added to the cooling tower fans.	Documentation including but not limited to product label, product catalogue, and written declaration with date-stamped photographs	+5	4.5.1.3

Criteria	Requirements	Verification	Points	Index
			+Bonus	
INNOSMART				
Innovations & Additions	Innovations & Additions: Incorporating various smart technologies to improve efficiency, reduce energy consumption, and optimize performance.	Narrative with supporting	+5	4.6.1
		Subtotal:	+70	

TABLE OF CONTENTS

1. INTRODUCTION.....	1
1.1 PURPOSE.....	1
1.2 BACKGROUND	2
2. SCOPE	2
3. DEFINITIONS	2
4. EVALUATION CRITERIA	4
4.1 BASIC INFORMATION.....	5
4.1.1 Product Information.....	5
4.2 CARBON	5
4.2.1 CFP quantification/EPD Report.....	5
4.3 RESOURCE	6
4.3.1 Circularity	6
4.3.2 Waste Management	7
4.3.3 Water Management	8
4.3.4 Energy Management.....	9
4.4 ENVIRONMENT.....	10
4.4.1 Environmental Management	10
4.4.2 Regional Product.....	10
4.4.3 Human Toxicity and Ecosystem Impact	10
4.5 PERFORMANCE	13
4.5.1 Efficiency Metrics	13
4.6 INNOSMART.....	15
4.6.1 Innovations & Additions	16
5. SCORING.....	17

1. INTRODUCTION

1.1 PURPOSE

The CIC Green Product Certification Scheme (the “Scheme”) is a green product labelling scheme, owned by the Construction Industry Council (CIC) and implemented by the Hong Kong Green Building Council (HKGBC). The primary goal of the scheme is to support Hong Kong’s transition to a low-carbon economy by encouraging the adoption of environmentally friendly construction practices.

With the Green Product Certification, various stakeholders, including consumers, building professionals, construction practitioners and policymakers, can easily and unequivocally identify environmentally preferable construction materials and building products. This certification serves as a reliable indicator of a product’s sustainability, helping to drive market demand for greener options.

To ensure the credibility and effectiveness of the certification, the CIC and the HKGBC has jointly developed this Technical Assessment Standards (the “Standard”), which sets out the assessment criteria and their benchmarks to govern the application and award of a label under the Scheme. The comprehensive assessment evaluates the overall sustainability of construction materials and building products across multiple dimensions. These dimensions include environmental impact, resource efficiency, technical performance, and the use of smart manufacturing technologies.

The Standard is divided into two main parts:

- General Requirements (Refer to General Requirements provided in separate document). This part introduces Scheme's framework, outlines the application procedure, and details the grades.
- Technical Requirements (This document refers). This part defines the principles, requirements and guides for quantifying and reporting the products’ carbon footprint (CFP), along with other sustainability assessment criteria and scoring standards.

This Standard neither modifies nor supersedes laws and regulations. Compliance with this Standard is not a substitute for, and does not assure, compliance with any applicable laws or regulations. Compliance with all applicable laws and regulations is a prerequisite for the manufacturing and marketing of the product.

1.2 BACKGROUND

Cooling tower is a device for lowering the temperature of water by evaporative cooling in which ambient air is in contact with falling water, thereby exchanging heat. Devices incorporating water refrigerant or water-water heat exchanger (evaporative condenser or closed-circuit cooling tower) are also included. “Evaporative” is used to term the type of heat rejection in a cooling tower because a small portion of water being cooled evaporates into a moving air stream to provide significant cooling to the rest of that water stream. The heat transferred from the water stream to the air stream raises the air temperature and its relative humidity to 100%, which is then discharged to the atmosphere.

Cooling tower can place a significant burden on the environment. With increasing environmental claims of cooling tower in the market, a more comprehensive and systematic approach to assess the environmental impacts of the cooling tower shall be developed. The aim of this Standard is to help designers and end-users choosing greener products by conserving resources, reducing the amount of waste disposal in landfills and reducing the impact to human health throughout the life cycle of air handling unit. The development of the assessment criteria in this Standard has made references to worldwide relevant eco-labelling schemes and some existing life cycle assessment (LCA) studies.

2. SCOPE

The scope of this Standard is applicable to different types of cooling towers, including open-circuit or closed-circuit, induced or forced draft, cross or counter flow, etc. Other components such as water pumps and chillers are not included in this Standard.

ONE application is only eligible for **ONE** product series with same serial number up to **5 (FIVE)** models. All the related products have to be listed on the submitted documents.

Subsequent application is available for similar products with the same product serial number of a labelled product series, which is only eligible for applying within the validity period of the label.

Note:

Each application should specify the product code / serial number.

3. DEFINITIONS

ASTM: American Society for Testing and Materials

GB: Chinese National Standards

BS: British Standards

BMS: Building Management System

<i>CIC:</i>	Construction Industry Council
<i>CNAS:</i>	China National Accreditation Service for Conformity Assessment
<i>HKAS:</i>	Hong Kong Accreditation Service
<i>HKGBC:</i>	Hong Kong Green Building Council
<i>HOKLAS:</i>	The Hong Kong Laboratory Accreditation Scheme
<i>ISO:</i>	International Organisation for Standardisation
<i>MSDS:</i>	Material Safety Data Sheet. To qualify as suitable, MSDS and information therein must not be more than 5-years old
<i>MiMEP:</i>	Multi-trade integrated Mechanical, Electrical and Plumbing

4. EVALUATION CRITERIA

A product to be assessed shall meet all the minimum requirements of the “Core Criteria” in order to be awarded a “Green” (i.e. a “pass” grade) Label under the Scheme. Bonus points may be awarded if the product meets the “Non-core Criteria”. “Bronze”, “Silver”, “Gold” or “Platinum” Label will be awarded according to the total points accumulated, as shown in Table 1.

Table 1 Benchmarks for grading

Points achieved	Grade to be awarded
90 or above	Platinum
80 – 89	Gold
70 – 79	Silver
60 – 69	Bronze
50 – 59	Green
Below 50	No label

All submissions and documentations shall be endorsed by the Chief Executive Officer or other authorised persons of the Applicant to demonstrate conformance to the assessment criteria. All certification, laboratory report and documentation must be valid during the assessment process and labelling period. The validity of all laboratory report and documentation shall be within 5 years from the date of issue. The chemical tests should be conducted by either a third party or the manufacturer, providing that they have obtained ISO 17025 certification or relevant national accreditations, such as HOKLAS or CNAS.

4.1 BASIC INFORMATION

4.1.1 Product Information – Core Criteria

The Applicant is required to achieve 5 Basic Points under this section.

Requirements

5 Basic Points for providing the following product information the following product information for compliance:

- Country of origin
- Basic product specifications
- Installation method
- Instructions for consumer product disposal
- Operation & Maintenance Manual

Verification

Documentation including but not limited to product label, product catalogue, MSDS, and written declaration with date-stamped photographs.

4.2 CARBON

4.2.1 CFP quantification/EPD Report – Non-core Criteria

The Applicant can achieve maximum 5 Bonus Points under this section.

Requirements

5 Bonus Points for providing life cycle assessment report for quantifying and reporting the carbon footprint of products (CFP), covering at least A1 (raw material supply), A2 (transport) and A3 (manufacturing process). This can be achieved by either of the following:

Conduct CFP study report in accordance with ISO 14067:2018 and CIBSE TM 65 or equivalent

OR

Provide the product's CFP value from a product level EPD issued in accordance with ISO 14067:2018, ISO 21930:2017, GB/T 24067-2024 or BS EN 15804:2012+A2:2019.

Verification

CFP quantification report endorsed by a third-party critical review or Environmental Product Declaration fulfilling the above requirements

4.3 RESOURCE

4.3.1 Circularity

The Applicant can achieve maximum 15 Bonus Points under this section.

4.3.1.1 Recyclability – Non-core Criteria

Requirements

5 Bonus Points for demonstrating that the manufacturer has developed a recycling plan for the product and declared options for reuse, recycling, recovery and disposal. The plan shall include the following and made available to public.

- Designate all homogeneous materials in the product as being intended for technical and/or biological cycles and define the intended cycling pathway(s) for each material.
- Identify potential partners for product reuse, recycling, recovery in accordance with the intended cycling pathway(s).
- For products and materials intended for municipal recycling, the product and/or material must be compatible for municipal cycling systems (e.g., painted plastics and plastic laminated paper are not currently compatible for municipal recycling).
- Instructions for how to cycle the product shall be made publicly available.

Verification

Documentation of recycling plan, including, but not limited to product catalogue, MSDS and written declaration

4.3.1.2 Packaging Requirements – Non-core Criteria

Requirements

5 Bonus Points for minimizing the wastage from all primary packaging materials. The packaging materials shall achieve either of the followings:

The packaging materials shall not contain halogenated plastics

OR

The packaging materials shall be comprised of 100% recycled materials, readily recyclable materials or decomposable materials

OR

The packaging shall not be impregnated, labelled, coated or otherwise treated in a manner, which would prevent or significantly limit recycling.

The packaging requirements are relevant to all primary packaging materials, i.e. those being used to envelop the product and hold it. The primary packaging materials are

usually in direct contact with the contents and shall be in the minimal amount of distribution and /or use as they may eventually be disposed by the consumers.

Verification

Documentation describing the packaging materials used as well as their chemical composition (if any and where applicable), treatment process and recyclability.

4.3.1.3 Design for Disassembly– Non-core Criteria

Requirements

5 Bonus Points for the cooling tower incorporated design for disassembly features, specifically:

- The fans and motors shall be demountable from enclosure for cleaning, repair, replacement or maintenance purpose.
- Fan impeller scroll casing shall be removable for fan blades cleaning.

Verification

Documentation including but not limited to product label, product catalogue, and written declaration with date-stamped photographs

4.3.2 Waste Management

The Applicant can achieve maximum 5 Bonus Points under this section.

4.3.2.1 Waste Management Plan– Non-core Criteria

Requirements

5 Bonus Points for implementing effective waste management plan detailing the policies, procedures and/or a waste management program covering manufacturing operations. The waste management plan should include but not limited to the following information:

- Initiatives taken to reduce waste generation and improve recovery/recycling of waste
- Initiatives implemented for recovery of post-consumer and/or pre-consumer waste that can be re-introduced into the manufacturing process and
- Other environmental benefits or constraints associated with waste minimisation objectives and processes.

Verification

Documentation of waste management programme.

4.3.3 Water Management

The Applicant can achieve maximum 10 Bonus Points under this section.

The Applicants can select one of the options below and comply with any or all the requirements under that option to achieve associated points. Each option is eligible for a maximum 10 Bonus Points.

Option A:

4.3.3.1 Water Consumption Reporting – Non-core Criteria

Requirements

5 Bonus Points for reporting both potable and non-potable water usage in the production process of the past year.

Verification

Water consumption report, support by water usage data acquired from water meter, water sub-meter, water bill or other equivalent documents.

4.3.3.2 Water Recycling Program– Non-core Criteria

Requirements

5 Bonus Points for developing and implementing water recycling program during the manufacturing process.

Verification

Documentation demonstrating the implementation of water recycling program, support by drawings, water usage data acquired from water sub-meter or other equivalent documents.

Option B:

4.3.3.3 Water Management System– Non-core Criteria

Requirements

10 Bonus Points for possessing valid certificate under ISO 14046: Environmental management – Water footprint – Principles, requirements and guidelines.

ISO 14046 is a framework for assessing the water footprint of products, processes, and organizations. It provides principles, requirements, and guidelines for conducting and reporting water footprint assessments. It helps organizations evaluate and improve their water management practices.

Verification

A valid ISO 14046 certificate issued by accredited certification body.

4.3.4 Energy Management

The Applicant can achieve maximum 10 Bonus Points under this section.

The Applicants can select one of the options below and comply with any or all the requirements under that option to achieve associated points.

Option A:

4.3.4.1 Energy Management Plan – Non-core Criteria

Requirements

5 Bonus Points for implementing effective energy management policies and procedures and/or an energy management programme, including but not limited to the following items:

- Energy efficiency initiatives: Manufacturer should undertake specific initiatives to reduce energy use and improve energy efficiency throughout their operations. This could include upgrading to more efficient equipment, optimizing production processes, or implementing energy-saving technologies
- Supplier requirements: Manufacturers should extend their energy management efforts to their supply chain by establishing requirements or initiatives for suppliers and contract manufacturers to improve their energy performance where possible

Verification

Documentation of Energy Management Plan detailing the above, supported by organizational policy or other equivalent documents.

Option B:

4.3.4.2 Energy Management System– Non-core Criteria

Requirements

10 Bonus Points for possessing valid certificates under ISO 50001: Energy management systems — Requirements with guidance for use.

ISO 50001 provides a framework for organizations to establish, implement, maintain, and improve an Energy Management System. The goal is to help organizations improve their energy performance, increase energy efficiency, and reduce energy costs and greenhouse gas emissions. By achieving ISO 50001 certification, manufacturers can demonstrate their commitment to energy efficiency and sustainability

Verification

A valid ISO 50001 certificate issued by accredited certification body.

4.4 ENVIRONMENT

4.4.1 Environmental Management

The Applicant can achieve maximum 5 Bonus Points under this section.

4.4.1.1 Environmental Management System – Non-core Criteria

Requirements

5 Bonus Points for possessing valid certificate under ISO 14001: Environmental management systems — Requirements with guidance for use or EU Eco-Management and Audit Scheme (EMAS).

The target of the environmental management system shall be set to reduce the environmental impacts during the manufacturing process which include but not limited to the reduction of hazardous substance emissions, energy consumption, CO₂ emissions, secondary environmental load, waste management, water management, etc.

ISO 14001 is the international standard which provides an outline of how to meet the environmental policy and objectives for the business of the applicant.

Eco-Management and Audit Scheme (EMAS) is an environmental management tool which enables organisations to assess, manage and continuously improve their environmental performance.

Verification

A valid ISO 14001 or EMAS certificate issued by accredited certification body.

4.4.2 Regional Product

The Applicant can achieve maximum 5 Bonus Points under this section.

4.4.2.1 Regional Manufactured Equipment – Non-core Criteria

Requirements

5 Bonus Points for products that are manufactured within 800km radius of HKSAR by road transportation; within a 1,600km radius by rail transportation; or within a 4,000km radius by sea transportation. The distance is measured by the direct distance, not by actual travel distance.

Verification

Documents demonstrating the location of the manufacturer and a map showing the distance between the manufacturer and HKSAR.

4.4.3 Human Toxicity and Ecosystem Impact

The Applicant is required to achieve 10 Basic Points under this section. Additionally, the Applicant can achieve maximum 5 Bonus Points under this section.

4.4.3.1 Hazardous Substances – Non-core Criteria

Requirements

5 Bonus Points are awarded for meeting both paint requirements and flame retardant requirements.

Paints Used

Limit the concentration of Lead, Cadmium, Chromium (VI), Mercury or their compounds in paint below 0.01% by weight.

Limit the concentration of VOC content in paint below 250g/L.

Flame Retardant

Concentration of the flame-retardants in the product shall be below 0.1% by weight of the product. The restricted fire retardants including the following types:

- Polybrominated diphenyl ether
- Polybrominated biphenyls
- Short-chained chlorinated paraffin
- Halogenated organic compound
- Hexabromocyclododecane

Products shall be tested based on the requirement as stated in BS 62321:2009 (or latest version); other related testing methods are also acceptable with justification provided by the applicant.

BS EN 62321:2009 specifies the determination of the levels of brominated flame retardants, polybrominated biphenyls (PBB) and polybrominated diphenyl ethers (PBDE) contained in electrotechnical products.

Verification

Laboratory test report(s) or self- declaration letter.

Test report(s) shall be compiled according to the National and International test methods including but not limited to IEC 62321.

4.4.3.2 Noise Level – Core Criteria

Requirements

10 Basic Points are awarded if the product meets the limits specified in Table 2 and Table 3. Products shall be tested based on the requirement as stated in GB/T 7190.1:2018 and GB/T 7190.2:2018 (or latest version); other related testing methods are also acceptable with justification provided by the applicant.

Table 2: Noise levels of cooling towers with cooling water capacity < 1,000m³/h

Nominal cooling water capacity (m ³ /h)	Noise levels dB (A)			
	Ordinary type	Low noise type	Ultra-low noise type	Industrial type
8	63.0	58.0	53.0	70.0
15	64.0	59.0	54.0	70.0
30	65.0	60.0	55.0	70.0
50	66.0	61.0	56.0	70.0
75	67.0	62.0	57.0	70.0
100	68.0	63.0	58.0	75.0
150	69.0	64.0	59.0	75.0
200	70.0	65.0	60.0	75.0
300	71.0	66.0	61.0	75.0
400	72.0	67.0	62.0	75.0
500	73.0	68.0	63.0	78.0
600	73.5	69.0	64.0	78.0
700	74.0	69.5	65.0	78.0
800	74.5	70.0	66.0	78.0
900	75.0	70.5	67.0	78.0
1,000	75.5	71.0	68.0	78.0

Table 3: Noise levels of cooling towers with cooling water capacity $\geq 1000\text{m}^3/\text{h}$

Types	Nominal cooling water capacity Q (m^3/h)	Noise levels db(A)
Counterflow	$1,000 \leq Q < 2,000$	78.0
	$2,000 \leq Q < 3,000$	79.0
	$3,000 \leq Q$	80.0
Crossflow	$1,000 \leq Q < 2,000$	74.0
	$2,000 \leq Q < 3,000$	75.0
	$3,000 \leq Q$	76.0

GB/T 7190.1:2018 specifies the classification of small and medium cooling tower products, technical requirements, test methods, inspection rules, signs, packaging, transport, storage and others. This section applies to a single tower cooling water is less than $1000\text{m}^3/\text{h}$, mechanical draft, equipped with water spray filler mixed structure open cooling tower.

GB/T 7190.2:2018 specifies the large cooling towers Products, technical requirements, test methods, inspection rules, signs, packaging, transport, storage and others. This section applies to the cooling water flow rate of not less than $1000\text{m}^3/\text{h}$ of mechanical draft cooling tower industry.

Verification

Documentation including but not limited to product catalogue and test report(s).

4.5 PERFORMANCE

4.5.1 Efficiency Metrics

The Applicant is required to achieve 35 Basic Points under this section. Additionally, the Applicant can achieve maximum 20 Bonus Points under this section.

4.5.1.1 Energy Efficiency – Core Criteria

Requirements

Points are awarded if the products meet the following efficiencies:

Table 4: Efficiency levels

Points	Efficiency levels
15 Basic Points	Baseline efficiency
5 Bonus Points	Exceed the baseline efficiency in the Table 5 by 10%
10 Bonus Points	Exceed the baseline efficiency in Table 5 by 15%

Table 5: Performance requirements (Ref: ASHRAE 90.1-2022-TABLE 6.8.1-7) Fan with open circuit type shall follow the latest BEC code and for the fan with closed circuit shall follow latest version of ASHRAE 90.1)

Equipment type	Rating condition	Performance required	Test procedure
- Propeller type - Axial fan open circuit type	35.0°C entering water 29.4°C leaving water 23.9°C entering wet-bulb	$\geq 3.40 \text{ L/s}\cdot\text{kW}$	CTI ATC-105 and CTI STD-201 RS
Centrifugal fan open circuit type	35.0°C entering water 29.4°C leaving water 23.9°C entering wet-bulb	$\geq 1.70 \text{ L/s}\cdot\text{kW}$	CTI ATC-105 and CTI STD-201 RS
- Propeller type - Axial fan closed circuit type	38.9°C entering water 32.2°C leaving water 23.9°C entering wet-bulb	$\geq 1.36 \text{ L/s}\cdot\text{kW}$	CTI ATC-105S and CTI STD-201 RS
Centrifugal fan closed circuit type	38.9°C entering water 32.2°C leaving water 23.9°C entering wet-bulb	$\geq 0.59 \text{ L/s}\cdot\text{kW}$	CTI ATC-105S and CTI STD-201 RS

For purposes of this table, open-circuit cooling tower performance is defined as the water flow rating of the tower at the thermal rating condition divided by the fan motor nameplate power.

For purposes of this table, closed-circuit cooling tower performance is defined as the process water flow rating of the tower at the thermal rating condition divided by the sum of the fan motor nameplate power and the integral spray pump motor nameplate power.

Verification

Documentation including but not limited to product catalogue and test report(s).

4.5.1.2 Water Efficiency – Core Criteria

Requirement

10 Basic Points are awarded for the product demonstrate the evaporation loss and drift loss shall not exceed 1% and 0.005% of water circulation rate respectively, under maximum air flow and maximum water flow.

Verification

Documentation including but not limited to product catalogue and test report(s).

4.5.1.3 Variable Speed Drives – Non-core Criteria

Requirement

5 bonus points are awarded if Variable Speed Drives (VSDs) are added for the cooling tower fans.

Verification

Documentation including but not limited to product label, product catalogue, and written declaration with date-stamped photographs.

4.5.1.4 Thermal Performance – Core Criteria

Requirements

Points are awarded for demonstration compliance that under the following specific operating conditions as stated in Table 6, the percentage of the measured cooling capacity and the designed cooling capacity shall not be less than the following limit:

- 10 Basic points: $\geq 90\%$
- 10 Basic points + 5 Bonus points: $\geq 95\%$

Table 7: Standard Rating Condition

Operating Conditions	Types of cooling tower		
	Open Circuit Cooling Tower	Closed Circuit Cooling Tower	Evaporative Refrigerant Condenser
Fluid	Water	Water	Ammonia
Inlet Fluid temperature/°C	35.0	38.9	-
Outlet Fluid Temperature/°C	29.4	32.2	35.7
Wet bulb temperature/°C	25.6	25.6	25.6

Products shall be tested based on the requirement as stated in CTI STD 201; other related testing methods are also acceptable with justification provided by the applicant.

Note:

CTI STD 201 specifies the performance rating of evaporative heat rejection equipment.

Verification

Documentation including but not limited to product catalogue and test report(s).

4.6 INNOSMART

The Applicant can achieve maximum 5 Bonus Points under this section.

4.6.1 Innovations & Additions – Non-core Criteria

Requirements

5 Bonus Points for achieving significant, measurable environmental performance using new practices, technology and strategy not addressed in this Standard.

Products shall be able to adopt with Multi-trade Integrated MEP (MiMEP) via technologies to facilitate including but not limited to BIM, Virtual Reality, RFID, wireless communication and Augmented Reality for improving efficiency and streamline manufacturing processes from MiMEP.

OR

Incorporating various smart technologies to improve efficiency, reduce energy consumption, and optimize performance as, exemplified by the following examples:

- Multi-trade Integrated MEP (MiMEP)
- Smart Controls and Automation
- IoT Integration and Data Analytics
- Energy-Efficient Designs

Verification

Report with a maximum length of 1,000 words, outline the objectives, solution and evaluation of the performance achieved by proposed Smart and Innovative Technologies.

AND

Include attachments that provide evidence of implementation, along with relevant technical specification that support the claims made in the report.

5. SCORING

The points for meeting each criterion stated in this Standard are summarized below.

Table 8: Points to be awarded under the assessment criteria of this Standard

Label	Evaluation criteria		Points		Related BEAM Plus Credits
			Basic	+Bonus	
	Product Information [CORE]		5	-	
Carbon	CFP quantification		-	+5	MW 10
Resource	Circularity	Recyclability	-	+5	
		Package Requirement	-	+5	
		Design for Disassembly	-	+5	
	Waste Management	Waste Management Plan	-	+5	
	Water Management	Water Consumption Reporting	-	+5/+10	
		Water Recycling Program	-		
		Water Management System	-		
	Energy Management	Energy Management Plan [CORE]	-	+5/+10	
		Energy Management System	-		
Environment	Environmental Management	Environmental Management System	-	+5	
	Regional Product	Regional Manufactured Equipment	-	+5	
	Human Toxicity and Ecosystem Impact	Hazardous Substance	-	+5	
		Noise Level [CORE]	10	-	SS 5
Performance	Efficiency Metrics	Energy Efficiency [CORE]	15	+5/+10	EU 2,3
		Water Efficiency [CORE]	10	-	
		Variable Speed Drive	-	+5	EU 2,3
		Thermal Performance [Core]	10	+5	
InnoSmart	Innovations & Additions		-	+5	IA
Total:			50	+85	

Related BEAM Plus Credits refer to these relevant credits under BEAM Plus New Buildings Version 2.0, as listed below.

- SS 5 – Noise Control for Building Equipment
- EU 2: Reduction of CO2 Emissions
- EU 3: Peak Electricity Demand Reduction
- MW 10: Life Cycle Assessment
- MW 9: Use of Green Products
- Innovations & Additions